

September 20, 2018

**Century Park Arboretum Island Tree Removal Project**

**Addendum I**

**Stump grinding requirements adjustment**

- Stumps on slopes too steep to approach with stump grinders will be flush cut as possible to ground level
- Stumps located over spaces between light poles to be ground to 3" instead of 6", ground will NOT be marked for power. 3" will be a safe depth.