

James Kim Vernon Hills Park District 635 Aspen Drive Vernon Hills, IL 60061

October 6, 2020

Re: Addendums to Sullivan Center Asphalt 2020

There are 4 addendums to the Sullivan Center Asphalt 2020 Bid. In addition, please replace attached documents within the bid document. Please include this Addendum when submitting public bid.

- 1. Bid Form and Pricing Sheet p. 14
 - a. Clarification of "Removal and Replace"
 - **b.** Concrete Footer Addition
- 2. Concrete Footers in Old Skate Park Location
 - a. 10 ct. Footers Dimensions: 17" x 17" with depth of 20"-22"
 - b. Each Footer has cut off bolts or bolt anchors inside concrete footer.
 - c. Alternative 1: Grinding Concrete Footers at 1 1/2" and Replace with HMA
 - d. Alternative 2: Removal of Existing Concrete Footers. Add stone, compact, and replace with HMA
- 3. Clarification
 - a. No 110% Performance, Labor, and Material Bond is Required see p.9
 - b. 10% Bid Bond is Required
 - c. Correction to p.6 BID REQUEST: Sullivan Center Asphalt 2020
 - d. Correction to p. 31 Pavement Marking Total Count 9
- 4. Map of parking lot
 - a. Orange is outline
 - b. Yellow is no parking area near skate park
 - c. Green lines are cross walks

